Exova Warringtonfire Holmesfield Road Warrington WA1 2DS United Kingdom T: +44 (0) 1925 655 116 F: +44 (0) 1925 655 419 E: warrington@exova.com W: www.exova.com

Testing. Advising. Assuring.



Title:

CLASSIFICATION OF REACTION TO FIRE PERFORMANCE IN ACCORDANCE WITH EN 13501-1: 2007 +A1: 2009

Notified Body No:

0833

Product Name:

"Probe Steel Products"

Report No:

351865

Issue No:

1

Prepared for:

Lion Steel Equipment Limited Johnson Brook Road, Hyde, Cheshire, SK14 4RB

Date:

14th May 2015

1. Introduction

This classification report defines the classification assigned to "Steel Lockers", powder coated steel sheet, in accordance with the procedures given in EN 13501-1:2007 +A1: 2009

2. Details of classified product

2.1 General

The product, "Steel Lockers", powder coated steel sheet is defined as suitable for construction applications, excluding flooring or linear pipe insulation.

2.2 Product description

The product, "Steel Lockers", powder coated steel sheet, is fully described below and in the test reports provided in support of classification listed in Clause 3.1.

General description		Powder coated steel	
Product reference of composite		"Steel Lockers"	
Name of manufacturer of composite		Lion Steel Equipment Limited	
Thickness of composite		0.9mm	
Weight per unit area of composite		6.86kg/m ²	
	Generic type	Epoxy polyester	
	Colours tested	"1 x Red,1 x Black, 1 x White"	
	Product reference	"AM03003000423 (Red)"	
		"AM03204000523 (Black)"	
Castina		"AM03009004423 (White)"	
Coating	Name of manufacturer	Axalta Powder Coating Systems UK Ltd	
(test face)	Number of coats	1	
	Application thickness	60 – 80 microns	
	Specific gravity	1.77	
	Application method	Electrostatic spray application	
	Flame retardant details	See Note 1 Below	
	Curing process per coat	10 minutes at 180°C	
	Generic type	Cold reduced steel	
Substrate	Product reference	"Steel"	
	Thickness	0.7mm-0.9mm	
	Weight per unit area	7850kg/m ³	
Air space details		A 80mm ventilated cavity was situated between the	
		reverse face of each specimen and the calcium silicate	
		backing board (as specified in EN 13238: 2010)	
Brief description of manufacturing process		See Note 3 Below	

Note 1: The sponsor of the test has confirmed that no flame retardant additives were utilised in the production of the product.

Note 2: The sponsor of the test was unwilling to provide this information

Note 3: The sponsor of the test was unable to provide this information

3. Test reports & test results in support of classification

3.1 Test reports

Name of Laboratory	Name of sponsor	Test report Nos.	Test method
Exova warringtonfire	Lion Steel Equipment Limited	WFR 350555	EN 13823
Exova warringtonfire	Lion Steel Equipment Limited	WFR 350556	EN ISO 1716

3.2 Test results

		No. tests	Results	
Test method & test number	Parameter		Continuous parameter - mean (m)	Compliance parameters
	PCS Coating	3	16.2242 MJ/kg	
EN ISO 1716	external non- substantial component		2.297 MJ/m ²	Compliant
	product as a whole		0.418 MJ/kg	Compliant
	FIGRA _{0.2MJ}		4.3	Compliant
	THR _{600s}		0.87	Compliant
	LFS		N	Compliant
EN 13823	SMOGRA	3	0.3	Compliant
	TSP _{600s}		31.5	Compliant
	Flaming droplets (y/n) <10 s (y/n) >10 s (y/n)		nil	Compliant

4. Classification and field of application

4.1 Reference of classification

This classification has been carried out in accordance with clause 8 of EN 13501-1:2007 +A1: 2009

4.2 Classification

The product, "Steel Lockers", powder coated steel sheet, in relation to its reaction to fire behaviour is classified:

Reaction to fire classification: A2-s1, d0

4.3 Field of application

This classification is valid for the following end use applications:

- i) Wall and ceiling applications
- ii) Used against any substrate of class A2 or better, with a density of 870 kg/m³ or higher
- iii) Free-standing

This classification is also valid for the following product parameters:

Product thickness 0.7 mm or more

Colour any

Product composition No further variation allowed

5 Limitations

This classification document does not represent type approval or certification of the product.

SIGNED APPROVED

.....

Frans Paap
Certification Engineer
Technical Manager

on behalf of Exova warringtonfire

This copy has been produced from a .pdf format electronic file that has been provided by Exova Warringtonfire to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of Exova Warringtonfire. The pdf copy supplied is the sole authentic version of this document. All pdf versions of this report bear authentic signatures of the responsible Exova Warringtonfire staff.

Date of Issue; 14th May 2015